



Memorandum of Policy

Building Codes

From: Mitch Miller

Date: November 9, 2018

Approved: Mike Metheny

Date: November 12, 2018

Subject: Use of Dimmer Controlled Receptacles

It is the policy of this Jurisdiction that the use of dimmer controlled receptacles is an acceptable wiring method.

A receptacle supplying lighting loads shall not be connected to a dimmer unless the plug/receptacle combination is specifically listed and identified for each such dimming application.