



Memorandum of Policy

Building Codes

From: Mike Metheny

Date: March 11, 2019

Revised:

Date: March 11, 2019

Subject: Insulation Under Snowmelt Concrete Slabs

It is the policy of this jurisdiction that, when a concrete slab containing a snowmelt system is installed, R10 insulation shall be installed under the area to be snow melted. Permeable snowmelt systems shall have insulation with an area-weighted average R-value equal to R10.

When existing snowmelt systems are being replaced or repaired the snowmelt system controls shall not be required to be placed within the slab.