



Memorandum of Policy

Building Codes

From: Mike Metheny

Date: March 11, 2019

Revised:

Date: March 11, 2019

Subject: Use of Tray Cable in Concealed Spaces

It is the policy of this jurisdiction that tray cable is an acceptable wiring method in concealed spaces in two specific conditions:

#1 - When used in lighting systems of 30 volts or less as described in article 411 of the adopted edition of the Nation Electrical Code.

#2 - Wiring referenced in article 725 of the adopted edition of the Nation Electrical Code for Class 2 and 3 installations.